



Together, Building
a Better California

This document references the interruption of power that began at approximately 10:34 a.m. on October 26, 2017.

The above outage was caused when a tractor trailer owned and operated by Dillard Trucking, Inc. (Dillard) veered off of the road and struck an electric transmission utility pole near the intersection of Highway 4 and Marsh Creek Rd. in Byron, CA. That incident caused a fault on a transmission circuit serving the Brentwood substation and resulted in the operation of a substation circuit breaker. 2,902 customers were affected by the outage. Pacific Gas and Electric (PG&E) crews worked diligently to repair the damaged pole as quickly and safely as possible and restored power to all affected customers by 12:05 a.m. the next day.

Dillard's insurance company and contact information are:

Laurie Stone
York Risk Services Group
E-mail: laurie.stone@yorkrsg.com
Office: 321-578-5162
Toll Free Phone: 800-469-2608 Ext. 5785162
Fax: 800-921-7683
Claim: #6569630
Policy #SISIPCA08347417

For questions, you can call PG&E at 1-800-743-5000.

Best Regards,

A handwritten signature in black ink, appearing to be the initials 'VB' or a similar stylized name.

Vic Baker
Senior Manager
Pacific Gas and Electric
1850 Gateway Blvd
Concord, CA 94520